

Message

From: Bennett, James [bennett.james@epa.gov]
Sent: 8/18/2017 1:41:50 PM
To: Reinhart, Roger [Reinhart.Roger@epa.gov]
Subject: RE: LAsT minute request

Thank you Roger

From: Reinhart, Roger
Sent: Friday, August 18, 2017 9:32 AM
To: Bennett, James <bennett.james@epa.gov>
Subject: Re: LAsT minute request

Jim - Here are my comments to the PFAS Sites write-ups.

DuPont/Chemours - Washington Works facility began using GenX in May 2013. The current version has two contradicting statements pertaining to this.

NAWC - "unregulated contaminant monitoring *rule*" not report. The wells will be pumped and treated with temporary GAC and discharged to waste. After about 90 days the wells will be sampled to determine whether the current ground level concentrations of PFOS and PFOA exceed the HA in which case the Navy will provide GAC treatment.

HAGS - . . . carbon treatment of stormwater discharging to streams which is believed to be impacting numerous nearby public and private water wells.

Wallops Island - The Town of Chincoteague is also considering drilling new off-site water supply wells which would not be impacted by PFAS contaminants. The finished water for both the Town of Chincoteague and the Wallops facility continues to be non-detect for PFAS contaminants of concern (verify this with Steve Hirsh or Lorie Baker).

From: Bennett, James
Sent: Friday, August 18, 2017 8:18:43 AM
To: Reinhart, Roger
Subject: LAsT minute request

Roger I need this by 10
Can you help me edit this. IT is for Cecil's meeting with the State Secretaries
Lori helped draft a first copy based on something you put together last time